



Product Service

Attestation of Conformity

No. N8A 118905 0002 Rev. 00

Holder of Certificate: **Sunrover Power Co., Ltd.**
No.800 Wangjiang West Road, High-tech Zone
230088 Hefei City, Anhui Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062265301-00

Date, 2022-11-28

(Zhulin Zhang)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Attestation of Conformity

No. N8A 118905 0002 Rev. 00

Model(s):

SUNxxx-DE21M(20) (xxx=640-670 in steps of 5)
 SUNxxx-DE21M(19) (xxx=585-605 in steps of 5)
 SUNxxx-DE21M(18) (xxx=540-560 in steps of 5)
 SUNxxx-DE21M(17) (xxx=525-545 in steps of 5)
 SUNxxx-DE21M(16) (xxx=495-505 in steps of 5)
 SUNxxx-DE21M(15) (xxx=470-485 in steps of 5)
 SUNxxx-DE21M(14) (xxx=445-455 in steps of 5)
 SUNxxx-DE21M(13) (xxx=410-430 in steps of 5)
 SUNxxx-DE21M(12) (xxx=395-405 in steps of 5)
 SUNxxx-DE21M(11) (xxx=485-515 in steps of 5)
 SUNxxx-DE21M(10) (xxx=385-410 in steps of 5)
 SUNxxx-DE21M(09) (xxx=290-310 in steps of 5)
 SUNxxx-DE21M(08) (xxx=190-205 in steps of 5)
 SUNxxx-DE21M(07) (xxx=95-100 in steps of 5)
 SUNxxx-DE17S(15) (xxx=445-465 in steps of 5)
 SUNxxx-DE17S(14) (xxx=405-425 in steps of 5)
 SUNxxx-DE17S(13) (xxx=370-385 in steps of 5)
 SUNxxx-DE17S(12) (xxx=330-345 in steps of 5)
 SUNxxx-DE17S(11) (xxx=295-310 in steps of 5)
 SUNxxx-DE17S(10) (xxx=220-230 in steps of 5)
 SUNxxx-DE17S(09) (xxx=185-190 in steps of 5)
 SUNxxx-DE17S(08) (xxx=145-155 in steps of 5)
 SUNxxx-DE17S(07) (xxx=110-115 in steps of 5)
 SUNxxx-DE16S(14) (xxx=375-425 in steps of 5)
 SUNxxx-DE16S(13) (xxx=340-390 in steps of 5)
 SUNxxx-DE16S(12) (xxx=310-350 in steps of 5)
 SUNxxx-DE16S(11) (xxx=280-315 in steps of 5)
 SUNxxx-DE16S(10) (xxx=250-280 in steps of 5)
 SUNxxx-DE16S(09) (xxx=185-210 in steps of 5)
 SUNxxx-DE16S(08) (xxx=155-175 in steps of 5)
 SUNxxx-DE16S(07) (xxx=125-140 in steps of 5)
 SUNxxx-DE16S(06) (xxx=90-105 in steps of 5)
 xxx is standing for rated output power at STC.

Parameters:

Construction:	Framed with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500V DC
Fire Safety Class:	Class C according to UL790

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06